250 Watt Pulse Start Lamp

Lamp Type

ANSI Code

Bulb Shape Base Type

Bulb Finish

Rated Life

Operating Position

Initial Lumens Lumens Per Watt

PHOTOMETRIC

Lamp Lumen Depreciation (LLD)

Chromaticity Coordinates (CIE-x,y)

Color Rendering Index (CRI) R_a

PHYSICAL

Max. Overall Length (MOL)

Light Center Length (LCL)

Max. Base Temperature (°C)

Max. Bulb Temperature (°C)

Socket Pulse Rating (KV)

Luminaire Type


Effective Arc Length

Bulb Diameter

Correlated Color Temperature









Dia. =	3.5" (90mm)
MOL =	8.3" (211mm)
LCL =	5.0" (127mm)
Base =	Mogul (EX39)

MP 250W/BU/UVS/PS/740 GENERAL Characteristics ELECTRICAL

MH Pulse Star

Mogul (EX39)

20000 hours

Base Up ±15°

0.86 (86%) @ 8000

.385 .390

3.5" (90mm)

8.3" (211mm)

5.0" (127mm)

Open / Enclosed Rated

25.6 mm

210

400

4

Clear

23800

4000K

95

68

Lamp Watts	
Lamp Oper. Voltage	e (Nom.)

SUSTAINABILITY

Mercury Amount (mg)	25.8
Picograms of Hg per Mean Lumen Hour	63


64658

250


133

NOTES

- Lamp performance ratings published in this data sheet are based upon operation with approved electronic ballasts.
- Operation of position-rated lamps outside of their tolerances will result in poor performance.
- UV Shield eliminates nearly all UV emissions, reducing color fading and lens yellowing.
- Minimum Starting Temperature: -40°C/°F.
- To calculate nighttime Scotopic lumens, multiply the lumen rating by the S/P ratio.
- **LEED V3, MR CREDIT 4: Sustainable Purchasing Reduced Mercury in Lamps is awarded 1 point for projects which at least 90% of all mercury-containing lamps purchased during the performance
- period comply and meet the target for mercury content of 90 picograms per lumen-hour or less.



Lumen Maintenance



(800) 451-2606

6675 Parkland Blvd., Suite 100 Solon, Ohio 44139 USA E-mail: Venture_Lighting@VentureLighting.com **VentureLighting.com** THIS LAMP CONFORMS TO FEDERAL STANDARD 21 CFR 1040.30 Complies with (CE), Low Voltage (CE), WEEE and RoHS Directives

Warning: This lamp can cause skin burn and eye inflammation from shortwave ultraviolet radiation if outer envelope of the lamp is broken or punctured. Do not use where people will remain for more than a few minutes unless adequate shielding or other safety precautions are used. Lamps that will automatically extinguish when outer envelope is broken or punctured are commercially available.

22
8 P
SSI
992
Ľ-O
~

©2022 Venture Lighting International Venture Lighting and Uni-Form are registered trademarks of Venture Lighting International. Revis